



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of August, 2024



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/01/2024	<b>Time Reported:</b> 5:53 AM
<b>Date(s) Occurred:</b> 08/01/2024	<b>Time(s) Occurred:</b> 5:53 AM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference a fire alarm at the 3 <sup>rd</sup> floor kitchen area. The contractor stated he was cleaning the stove when a burner was left on and while cleaning caused smoke. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/08/2024	<b>Time Reported:</b> 10:16 AM
<b>Date(s) Occurred:</b> 08/08/2024	<b>Time(s) Occurred:</b> 10:16 AM
<b>Location:</b> Margaret Nance	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in room 134. The temperature was high in the room due to the extreme amount of steam coming from the boiler which caused the alarm. FM came to correct the problem.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/08/2024	<b>Time Reported:</b> 10:29 AM
<b>Date(s) Occurred:</b> 08/08/2024	<b>Time(s) Occurred:</b> 10:29 AM
<b>Location:</b> Bancroft Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in room 124. Steam from the boiler caused high temperatures which caused the alarm to sound. FM came to correct the problem.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/10/2024	<b>Time Reported:</b> 4:42 PM
<b>Date(s) Occurred:</b> 08/10/2024	<b>Time(s) Occurred:</b> 4:42 PM
<b>Location:</b> Withers Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in room 322C. There was no sign of smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/12/2024	<b>Time Reported:</b> 9:20 AM
<b>Date(s) Occurred:</b> 08/12/2024	<b>Time(s) Occurred:</b> 9:20 AM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to two trouble alarms. The officer reset the alarms and suggested that FM come and resolve the issue.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department

Daily Fire Log

Month of August, 2024



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/14/2024	<b>Time Reported:</b> 4:44 PM
<b>Date(s) Occurred:</b> 08/14/2024	<b>Time(s) Occurred:</b> 4:44 PM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm at the first floor gallery. There was no sign of smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/15/2024	<b>Time Reported:</b> 3:48 PM
<b>Date(s) Occurred:</b> 08/15/2024	<b>Time(s) Occurred:</b> 3:48 PM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The building was searched and there was no smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/17/2024	<b>Time Reported:</b> 4:30 PM
<b>Date(s) Occurred:</b> 08/17/2024	<b>Time(s) Occurred:</b> 4:30 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to the Courtyard in reference to a fire alarm. The alarm was showing the 4 <sup>th</sup> floor and a check of the building found no smoke or fire. FM responded to reset the alarm due to the smoke detector.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/19/2024	<b>Time Reported:</b> 1:59 PM
<b>Date(s) Occurred:</b> 08/19/2024	<b>Time(s) Occurred:</b> 1:59 PM
<b>Location:</b> E. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in room 206. There was no signs of smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/21/2024	<b>Time Reported:</b> 5:45 AM
<b>Date(s) Occurred:</b> 08/21/2024	<b>Time(s) Occurred:</b> 5:45 AM
<b>Location:</b> Walk2Campus	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm and responded to the room the alarm triggered from. There was no one there and there was no sign of smoke or fire.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department

Daily Fire Log

Month of August, 2024



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/21/2024	<b>Time Reported:</b> 11:36 PM
<b>Date(s) Occurred:</b> 08/21/2024	<b>Time(s) Occurred:</b> 11:36 PM
<b>Location:</b> Phleps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in room 224. The officer met with the occupant who stated it just started going off. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/25/2024	<b>Time Reported:</b> 11:09 AM
<b>Date(s) Occurred:</b> 08/25/2024	<b>Time(s) Occurred:</b> 11:09 AM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. The officer checked the rooms the alarm was coming from and there was no sign of smoke or fire. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/25/2024	<b>Time Reported:</b> 8:37 PM
<b>Date(s) Occurred:</b> 08/25/2024	<b>Time(s) Occurred:</b> 8:37 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm in room 232. The officer did find food in the shared kitchen. The officer removed the food and turned the oven/stove off.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/25/2024	<b>Time Reported:</b> 10:56 PM
<b>Date(s) Occurred:</b> 08/25/2024	<b>Time(s) Occurred:</b> 10:56 PM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded and there were no issues. FM responded to reset the alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/26/2024	<b>Time Reported:</b> 11:24 PM
<b>Date(s) Occurred:</b> 08/26/2024	<b>Time(s) Occurred:</b> 11:24 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in the electric room. There was no sign of smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of August, 2024



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/31/2024	<b>Time Reported:</b> 12:16 AM
<b>Date(s) Occurred:</b> 08/31/2024	<b>Time(s) Occurred:</b> 12:16 AM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm which was due to the power outage that occurred.	
<b>Disposition:</b> Complete	