



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of December, 2024



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/02/2024	<b>Time Reported:</b> 6:26 AM
<b>Date(s) Occurred:</b> 12/02/2024	<b>Time(s) Occurred:</b> 6:26 AM
<b>Location:</b> MacFeat House	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset. FM was also notified.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/03/2024	<b>Time Reported:</b> 8:24 AM
<b>Date(s) Occurred:</b> 12/03/2024	<b>Time(s) Occurred:</b> 8:24 AM
<b>Location:</b> MacFeat House	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated. There was no sign of smoke or fire and the alarm was reset. This has been an ongoing issue for the past week and FM was notified	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/03/2024	<b>Time Reported:</b> 11:50 PM
<b>Date(s) Occurred:</b> 12/03/2024	<b>Time(s) Occurred:</b> 11:50 PM
<b>Location:</b> Lee Wicker	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated. The officer reset the alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/04/2024	<b>Time Reported:</b> 8:21 AM
<b>Date(s) Occurred:</b> 12/08/2024	<b>Time(s) Occurred:</b> 8:21 AM
<b>Location:</b> McFeat House	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded regarding an alarm going off near the front door, the alarm was reset and Facilities was contacted because the alarm has been going off every morning.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/07/2024	<b>Time Reported:</b> 11:47AM
<b>Date(s) Occurred:</b> 12/07/2024	<b>Time(s) Occurred:</b> 11:47 AM
<b>Location:</b> DiGiorgio Campus Center	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer arrived and checked the area; the fire panel was advising a trouble alarm for the roof top duct detector. The officer did not observe and smoke or fire but had the on-call Facilities Management person contacted to check the area.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department



Daily Fire Log

Month of December, 2024

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/10/2024	<b>Time Reported:</b> 2:29 PM
<b>Date(s) Occurred:</b> 12/10/2024	<b>Time(s) Occurred:</b> 2:29 PM
<b>Location:</b> DiGiorgio Campus Center	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/16/2024	<b>Time Reported:</b> 12:56 PM
<b>Date(s) Occurred:</b> 12/16/2024	<b>Time(s) Occurred:</b> 12:56 PM
<b>Location:</b> Bancroft Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The office responded in reference to a fire alarm being activated. The panel advised water flow problem. The building was checked and no leak was visibly. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	